



NOTES:

1. ALL PIPE AND FITTINGS 2" AND SMALLER SHALL BE THREADED SCHEDULE 40 PVC OR BRASS.
2. PROVIDE PROTECTION AGAINST FREEZING.
3. TWO PIPE SUPPORTS REQUIRED.
4. ALL ITEMS ABOVE GRADE SHALL HAVE ONE COAT OF APPROVED RUST RESISTANT BLUE ENAMEL PAINT.

REDUCED PRESURE BACKFLOW PREVENTER
FOR 3/4, 1, 1-1/2 & 2"
NOT TO SCALE

REV	DATE	BY	REVISIONS
1	17 JULY 05	RAL	SWITCHED BALL VALVE AND UNION



REDUCED PRESURE BACKFLOW PREVENTER FOR 3/4, 1, 1-1/2 & 2"
TECHNICAL STANDARDS MANUAL
CITY OF LYNN HAVEN FLORIDA

CAD FILE:	WATER
DWN BY:	REF
DATE:	30 APR 07
SHEET NO:	21 OF 27
DETAIL	W-21

© CITY OF LYNN HAVEN ALL RIGHTS RESERVED. NO PART OF THIS DOCUMENT MAY BE REPRODUCED OR UTILIZED IN ANY FORM WITHOUT PRIOR WRITTEN AUTHORIZATION OF THE CITY OF LYNN HAVEN