



NOTES:

1. ALL FITTINGS SHALL BE BRASS WITH COMPRESSION/PACK JOINT REUSE TYPE CONNECTIONS.
2. ALL TUBING TO BE 200 PSI. PURPLE
3. ALL CURB STOPS SHALL BE LOCKABLE TYPE FORD GRIP SEAL – FOR REUSE.
4. ALL CORPORATION STOPS SHALL BE FORD GRIP SEAL – FOR REUSE.
5. PROVIDE INSERTS AT ALL CORPORATION AND CURB STOPS.
6. PROVIDE #14AWG PURPLE LOCATOR WIRE ALONG ENTIRE LENGTH OF TUBING.
7. NO SERVICE LINE SHALL TERMINATE UNDER A DRIVEWAY.
8. EACH SERVICE SHALL TERMINATE AT A CURB STOP WHICH SHALL BE BURIED APPROXIMATELY 3” BELOW FINAL GRADE AND SHALL BE CLEARLY MARKED WITH A 2” X 2” X 18” STAKE WITH THE TOP PAINTED PURPLE AND MARKED WITH THE NUMBER OF THE LOT TO BE SERVED.

RE-USE SERVICE CONNECTION DETAIL

REV	DATE	BY	REVISIONS
1	17 JULY 05	RAL	REVISED NOTES



RE-USE SERVICE  
 CONNECTION DETAILS  
 TECHNICAL STANDARDS MANUAL  
 CITY OF LYNN HAVEN FLORIDA

CAD FILE:	REUSE
DWN BY:	REF
DATE:	30 APR 07
SHEET NO:	2 OF 18
DETAIL	R-2