



- NOTES:
1. PVC EXTENSIONS SHALL NOT BE USED ON VALVE BOX INSTALLATION.
 2. THE ACTUATING NUT FOR DEEPER VALVES SHALL BE EXTENDED TO COME UP TO 4 FOOT DEPTH BELOW FINISHED GRADE.
 3. VALVE EXTENSION SHALL HAVE SET SCREW INTO 2" OPERATING NUT.
 4. ALL BELOW GRADE NUTS AND BOLTS SHALL BE STAINLESS STEEL
 5. ALL VALVE COVERS TO BE PAINTED WITH EXPOXY PAINT. WATERMAIN (BLUE), FORCEMAIN (GREEN), FIREWATER (RED) AND RE-USE (PURPLE)
 6. REFER TO R-5 FOR ADDITIONAL REQUIREMENTS FOR VALVES 10" & LARGER

GATE VALVE AND BOX DETAIL

NOT TO SCALE (R-10)

REV	DATE	BY	REVISIONS



TECHNICAL
STANDARDS
MANUAL

GATE VALVE AND
BOX DETAIL
TECHNICAL STANDARDS MANUAL
CITY OF LYNN HAVEN FLORIDA

CAD FILE:	REUSE
DWN BY:	REF
DATE:	30 APR 07
SHEET NO:	10 OF 18
DETAIL	R-10