



- NOTES:
1. BRONZE IDENTIFICATION DISC SHALL BE REQUIRED FOR ALL VALVES 10" AND LARGER, OR AS REQUIRED BY THE ENGINEER FOR CRITICAL OFFSITE VALVES.
 2. VALVE COLLAR DIMENSIONS MAY BE REDUCED TO 18" X 18" X 6" WHEN THE BRONZE IDENTIFICATION DISC IS NOT REQUIRED.

SEWER VALVE COLLAR DETAIL (12" & LARGER)

NOT TO SCALE

REV	DATE	BY	REVISIONS
1	25 MAR 13	REFJHJS	REVISED FOR FUTURE USE



TECHNICAL STANDARDS MANUAL

SEWER VALVE COLLAR DETAIL (12" & LARGER)
TECHNICAL STANDARDS MANUAL
 CITY OF LYNN HAVEN FLORIDA

CAD FILE:	SEWER
DWN BY:	REF
DATE:	30 APR 07
SHEET NO:	13 OF 20
DETAIL	S-13