



NOTES:

1. PVC EXTENSIONS SHALL NOT BE USED ON VALVE BOX INSTALLATION.
2. THE ACTUATING NUT FOR DEEPER VALVES SHALL BE EXTENDED TO COME UP TO 4 FOOT DEPTH BELOW FINISHED GRADE.
3. VALVE EXTENSION SHALL HAVE SET SCREW INTO 2" OPERATING NUT.
4. ALL BELOW GRADE NUTS AND BOLTS SHALL BE STAINLESS STEEL
5. ALL VALVE COVERS TO BE PAINTED WITH EXPOXY PAINT. WATERMAIN (BLUE), FORCEMAIN (GREEN), FIREWATER (RED) AND RE-USE (PURPLE)

SEWER GATE VALVE AND BOX DETAIL

NOT TO SCALE

REV	DATE	BY	REVISIONS
2	29 MAY 12	REFJMS	REVISED PER ENGINEER
1	20 JAN 11	REFJHHS	REVISED DETAIL



TECHNICAL  
STANDARDS  
MANUAL

SEWER GATE VALVE  
AND BOX DETAIL  
TECHNICAL STANDARDS MANUAL  
CITY OF LYNN HAVEN FLORIDA

CAD FILE:	SEWER
DWN BY:	REF
DATE:	30 APR 07
SHEET NO:	14 OF 20
DETAIL	S-14