



NOTES:

1. ALL FITTINGS SHALL BE NO-LEAD BRASS JOINT.
2. ALL PE TUBING CONNECTION SHALL BE COMPRESSION / PACK JOINT TYPE WITH STAINLESS STEEL INSERTS.
3. ALL TUBING SHALL BE PE4710-CIS SDR9 200PSI.
4. ALL CURB STOPS SHALL BE LOCKABLE TYPE FORD GRIP SEAL (B-433-42 WG-NL).
5. ALL CORPORATION STOPS SHALL BE FORD GRIP SEAL C44-44-WG-NL).
6. PROVIDE #12AWG LOCATOR WIRE ALONG ENTIRE LENGTH OF TUBING.
7. NO SERVICE LINE SHALL TERMINATE UNDER A DRIVEWAY.
8. EACH SERVICE SHALL TERMINATE AT A CURB STOP WHICH SHALL BE BURIED APPROXIMATELY 3" BELOW FINAL GRADE AND SHALL BE CLEARLY MARKED WITH A 2" X 2" X 18" STAKE WITH THE TOP PAINTED BLUE AND MARKED WITH THE NUMBER OF THE LOT TO BE SERVED AND TYPE OF SERVICE PROVIDED, i.e., POTABLE WATER OR RECLAIMED WATER.

WATER SERVICE CONNECTION DETAIL

REV	DATE	BY	REVISIONS
2	14 MAR 17	SEP	REVISED DETAIL & NOTES
1	03 JUN 11	REF/JHS	REVISED DETAIL TEXT



**TECHNICAL
STANDARDS
MANUAL**

**WATER SERVICE
CONNECTION DETAIL
TECHNICAL STANDARDS MANUAL**
CITY OF LYNN HAVEN FLORIDA

CAD FILE:	WATER
DWN BY:	REF
DATE:	30 APR 07
SHEET NO:	4 OF 27
DETAIL	W-4