



- NOTES:
1. BRONZE IDENTIFICATION DISC SHALL BE REQUIRED FOR ALL VALVES 10" AND LARGER, OR AS REQUIRED BY THE ENGINEER FOR CRITICAL OFFSITE VALVES.
 2. VALVE COLLAR DIMENSIONS MAY BE REDUCED TO 18" X 18" X 6" WHEN THE BRONZE IDENTIFICATION DISC IS NOT REQUIRED.

VALVE COLLAR DETAIL

NOT TO SCALE

REV	DATE	BY	REVISIONS
1	25 MAR 13	REFJHJS	REVISED DETAIL



TECHNICAL
STANDARDS
MANUAL

VALVE COLLAR
DETAIL
TECHNICAL STANDARDS MANUAL
CITY OF LYNN HAVEN FLORIDA

CAD FILE:	WATER
DWN BY:	REF
DATE:	30 APR 07
SHEET NO:	7 OF 27
DETAIL	W-7