



NOTES:

- 1.) NO CUTS SHALL BE MADE BEFORE:
 - (A) A TEST OF 180 OR 200 P.S.I. FOR 60 MINUTES IS MADE.
 - (B) ALL FITTINGS TO BE WRAPPED WITH 20 MIL VISQUEEN AT THRUST BLOCK
 - (C) ALL TAPS TO BE MADE BY THE CONTRACTOR AND MATERIAL TO BE FURNISHED BY THE CONTRACTOR
- 2.) ALL TAPS MUST BE OF A SMALLER SIZE THAN THE MAIN BEING TAPPED & PLACED NO CLOSER THAN 30" OR A DISTANCE EQUAL TO (1) MAIN PIPE DIAMETER PLUS (2) TAP PIPE DIAMETERS (WHICHEVER IS LARGER) FROM A JOINT OR FITTING.

TAPPING SLEEVE & VALVE BLOCKING DETAIL
NOT TO SCALE (W-10)

REV	DATE	BY	REVISIONS
1	03 JUN 11	REF	REVISED DETAIL TEXT



**TECHNICAL
STANDARDS
MANUAL**

**TAPPING SLEEVE AND
VALVE BLOCKING DETAIL**
TECHNICAL STANDARDS MANUAL
CITY OF LYNN HAVEN FLORIDA

CAD FILE:	WATER
DWN BY:	REF
DATE:	30 APR 07
SHEET NO:	10 OF 27
DETAIL	
W-10	