


**MULTI-METER EXAMPLE DETAIL**  
NOT TO SCALE

NOTE:  
NUMBER OF METERS MAY VARY. SEE SCHEDULE  
( 6 MAX PER 4" MANIFOLDS)  
(12 MAX PER 6" MANIFOLDS)

(\* ) METER AND METER BOXES BY CITY FOR 2" LINES AND SMALLER

(\*\* ) 2"x4" STAINLESS STEEL TAG WITH UNIT ADDRESS ENGRAVED. TAG TO BE PERMANENTLY ATTACHED.

NOTE:  
ALL 4"-12" PVC PIPE WITHIN RIGHT OF WAY SHALL BE AWWA C900 (DR18)



**MULTI-METER DETAIL**  
NOT TO SCALE

REV	DATE	BY	REVISIONS
2	13 MAR 15	JDM	ADDED BFP
1	18 MAY 11	REFIBEC	REVISED DETAIL AND ADDED NOTES



**TECHNICAL STANDARDS MANUAL**

**MULTI-METER DETAIL**  
TECHNICAL STANDARDS MANUAL  
CITY OF LYNN HAVEN FLORIDA

CAD FILE:	WATER
DWN BY:	REF
DATE:	30 APR 07
SHEET NO:	13 OF 27
DETAIL	W-13