



NOTES:

1. ALL PIPE AND FITTINGS 2" AND SMALLER SHALL BE THREADED SCHEDULE 40 PVC OR BRASS.
2. PROVIDE PROTECTION AGAINST FREEZING.
3. TWO PIPE SUPPORTS REQUIRED.
4. ALL ITEMS ABOVE GRADE SHALL HAVE ONE COAT OF APPROVED RUST RESISTANT BLUE ENAMEL PAINT.

BACKFLOW PREVENTER
NOT TO SCALE

REV	DATE	BY	REVISIONS
1	17 July 05	RAL	MOVE UNION TO INSIDE OF VALVE



**BACKFLOW
PREVENTER**
TECHNICAL STANDARDS MANUAL
CITY OF LYNN HAVEN FLORIDA

CAD FILE:	WATER
DWN BY:	REF
DATE:	30 APR 07
SHEET NO:	14 OF 27
DETAIL	
W-14	