



NOTES:

1. ABOVE DETAIL IS BASED ON 2" COMBINATION AIR/VACUUM RELEASE VALVE. CHANGE PIPE AND FITTINGS ACCORDINGLY FOR OTHER VALVE SIZES AND TYPES. VALVE SIZES TO BE DETERMINED BY THE ENGINEER AND APPROVED BY THE CITY.
2. THE MINIMUM DIMENSION FROM TOP OF PIPE TO FINISHED GRADE SHALL BE 4.0 FEET.
3. ALL VALVE & MH COVERS TO BE PAINTED WITH EXPOXY PAINT. WATERMAIN (BLUE), FORCEMAIN (GREEN), FIREWATER (RED) AND RE-USE (PURPLE)

AIR AND/OR VACUUM RELEASE VALVE DETAIL
NOT TO SCALE

REV	DATE	BY	REVISIONS
1	03 JUN 11	REF/JHS	REVISED DETAIL AND NOTES



**TECHNICAL
STANDARDS
MANUAL**

**AIR AND/OR VACUUM
RELEASE VALVE DETAIL
TECHNICAL STANDARDS MANUAL**
CITY OF LYNN HAVEN FLORIDA

CAD FILE:	WATER
DWN BY:	REF
DATE:	30 APR 07
SHEET NO:	20 OF 27
DETAIL	
W-20	

© CITY OF LYNN HAVEN ALL RIGHTS RESERVED. NO PART OF THIS DOCUMENT MAY BE REPRODUCED OR UTILIZED IN ANY FORM WITHOUT PRIOR WRITTEN AUTHORIZATION OF THE CITY OF LYNN HAVEN