

WATER AND REUSE VALVES

- 1.) 12" AND LESS SHALL BE EPOXY COATED RESILIENT SEAT GATE VALVES.
- 2.) 16" AND ABOVE SHALL BE EPOXY COATED RESILIENT BUTTERFLY VALVES.

REV	DATE	BY	REVISIONS
1	03 JUN 11	REF	REV. SHT. NO. TO ADD DIR. BORE DETAIL



TECHNICAL
STANDARDS
MANUAL

WATER AND REUSE
VALVE NOTES
TECHNICAL STANDARDS MANUAL
CITY OF LYNN HAVEN FLORIDA

CAD FILE:	WATER
DWN BY:	REF
DATE:	30 APR 07
SHEET NO:	26 OF 27
DETAIL	
W-26	